



Department of Energy

Washington, DC 20585

May 26, 2004

Mr. Roger Zavadoski
Defense Nuclear Facilities Safety Board
625 Indiana Avenue, NW, Suite 700
Washington, D.C. 20004-2941

Dear Mr. Zavadoski:

The Secretary of Energy, in his July 11, 2003 letter to the Defense Nuclear Facilities Safety Board (DNFSB) on High Efficiency Particulate Air (HEPA) filter testing, committed the Office of Environment, Safety and Health (EH) to publish a semiannual report on Filter Test Facility (FTF) data. This is the second report published by EH and includes FTF data for the first six months of FY 2004. The attached Table provides the results of filter inspections and tests performed at the FTF for the period October 1, 2003 through March 31, 2004.

The report indicates that the HEPA filter failures continue at a rate consistent with previous years. I also visited the FTF in February to observe testing. During that visit, a supplier repaired 36 defective HEPAs at FTF preventing delays in deliveries to DOE sites. Questions concerning this report may be directed to me at (301) 903-4218 or Chip.Lagdon@eh.doe.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Lagdon, Jr.", written over a horizontal line.

Richard H. Lagdon, Jr.
Director
Office of Quality Assurance Programs

Attachment

cc: Mark B. Whitaker, DR-1
Frank B. Russo, EH-3



Table 1
Results of Filter Inspection and Tests
October 1, 2003 - March 31, 2004

Customer	Manufacturer	Flow	Flow High/Low	Number Tested	Number Accepted	Number Rejected	Reason for Rejection			Rejection Rate	
							Resistance	Penetration	Manufacturing Defects		Does not meet PO and/or Spec
Bechtel BWXT Idaho, LLC.(BBWI)	Supplier A	1000	H	8	7	1			1		12.5%
	Supplier A	1000	H	40	36	4			3	1	10.0%
	Supplier A	1000	H	1	1	0					
	Supplier A	1000	H	111	111	0					
	Supplier A	100	L	2	2	0					
	Supplier A	35	L	6	6	0					
Bechtel BWXT Y-12	Supplier B	1500	H	4	3	1			1		25.0%
	Supplier B	1500	H	2	1	1				1	50.0%
	Supplier B	1000	H	1	0	1			1		100.0%
	Supplier A	1000	H	11	11	0					
	Supplier A	250	L	6	4	2			2		33.3%
	Supplier A	250	L	2	2	0					
	* Supplier A	100	L	24	12	12		2		10	
* Supplier A	50	L	4	4	0						
AEA Technology	Supplier A	1000	H	2	1	1				1	50.0%
	Supplier A	1000	H	1	1	0					
Bechtel Jacobs X-10	Supplier A	1000	H	12	12	0					
	Supplier A	1000	H	6	6	0					
Duratek Federal Services X10	Supplier A	1000	H	1	0	1			1		100.0%
	Supplier B	1000	H	5	5	0					
	Supplier B	125		1	1	0					
Foster Wheeler	Supplier C	2200	H	2	2	0					
	* Supplier C	2200	H	48	44	4		4			8.3%
	* Supplier C	2200	H	48	40	8		1		7	16.7%
	* Supplier C	2200	H	48	45	3				3	6.3%
	Supplier C	2200	H	5	5	0					
	Supplier C	2200	H	15	13	2			2		13.3%
UT Battelle	Supplier B	50	L	3	3	0					
	Supplier A	35	L	1	1	0					
BWXT Pantex, LLC	Supplier A	1000	H	8	7	1		1			12.5%
CH2M Hill Hanford	Supplier A	1500	H	20	20	0					
	Supplier A	1000	H	6	6	0					
	Supplier A	1000	H	6	6	0					
	Supplier A	1000	H	6	4	2		1		1	33.3%
	Supplier A	500	H	12	11	1		1			8.3%

Table 1
Results of Filter Inspection and Tests
October 1, 2003 - March 31, 2004

Customer	Manufacturer	Flow	Flow High/Low	Number Tested	Number Accepted	Number Rejected	Reason for Rejection			Rejection Rate		
							Resistance	Penetration	Manufacturing Defects		Does not meet PO and/or Spec	Shipping damage
CH2M Hill Hanford	Supplier A	500	H	1	0	1					100.0%	
	Supplier A	500	H	1	1	0				1		
	Supplier A	500	H	5	5	0						
	Supplier A	250	L	1	1	0						
	Supplier A	250	L	6	6	0						
	Supplier A	200	L	5	5	0						
	Supplier A	200	L	20	20	0						
	Supplier A	200	L	24	24	0						
	Supplier A	200	L	2	2	0						
Fluor Hanford	Supplier A	1500	H	4	4	0						
	Supplier A	1000	H	4	4	0						
	Supplier A	1000	H	9	9	0						
	Supplier A	250	L	6	6	0						
	Supplier A	125	L	5	5	0						
	Supplier A	125	L	4	4	0						
	Supplier A	50	L	8	8	0						
Kaiser-Hill Company LLC	Supplier A	1500	H	4	4	0						
	Supplier A	1500	H	16	16	0						
	Supplier A	1500	H	14	14	0						
	Supplier A	1500	H	90	88	2				2		2.2%
	Supplier A	1500	H	12	12	0						
	Supplier A	1500	H	2	2	0						
	Supplier A	1000	H	6	6	0						
Lawrence Livermore National Lab.	Supplier B	1500	H	1	1	0						
	Supplier B	1500	H	5	3	2			2			40.0%
	Supplier B	1500	H	2	1	1			1			50.0%
	Supplier A	1000	H	18	18	0						
	Supplier A	1000	H	4	4	0						
	Supplier A	1000	H	6	5	1		1				16.7%
	Supplier B	1000	H	65	63	2					2	3.1%
	Supplier B	1000	H	2	2	0						
	Supplier A	1000	H	30	30	0						
	Supplier A	1000	H	45	45	0						
	Supplier A	1000	H	1	1	0						
	Supplier A	105	H	3	3	0						
	Los Alamos National Laboratory	Supplier D	1500	H	3	3	0					
Supplier D		1500	H	1	1	0						
Supplier B		1500	H	1	1	0						
Supplier A		1250	H	6	6	0						
Supplier A		1000	H	100	97	3				3		3.0%

Table 1
Results of Filter Inspection and Tests
October 1, 2003 - March 31, 2004

Customer	Manufacturer	Flow	Flow High/Low	Number Tested	Number Accepted	Number Rejected	Reason for Rejection			Rejection Rate	
							Resistance	Penetration	Manufacturing Defects		Does not meet PO and/or Spec
Los Alamos National Laboratory	Supplier A	1000	H	3	3	0					
	Supplier A	1000	H	100	92	8			8		8.0%
	Supplier A	1000	H	100	98	2			2		2.0%
	Supplier A	1000	H	10	10	0					
	Supplier A	1000	H	30	30	0					
	Supplier A	350	H	2	2	0					
	Supplier A	250	L	2	2	0					
	Supplier A	250	L	2	2	0					
	Supplier A	205	L	1	1	0					
	Supplier A	160	L	1	1	0					
	Supplier A	50	L	20	20	0					
	Supplier A	50	L	20	20	0					
	Supplier A	35	L	20	20	0					
	Supplier A	35	L	20	20	0					
KSL Shaw Los Alamos National Laboratory	Supplier A	35	L	20	20	0					
	Supplier A	160	L	1	1	0					
Washington TRU Solutions	Supplier A	350	H	4	4	0					
West Valley Nuclear Services	**Supplier D	1500	H	12	12	0					
Westinghouse Savannah River Company	Supplier A	1500	H	94	83	11			11		11.7%
	Supplier A	1500	H	51	49	2				2	3.9%
	Supplier A	1500	H	22	21	1			1		4.5%
	Supplier A	1500	H	10	9	1				1	10.0%
	Supplier A	1500	H	20	19	1			1		5.0%
	Supplier A	1500	H	9	9	0					
	Supplier A	1500	H	28	27	1			1		3.6%
	Supplier A	1500	H	146	135	11		1	5	5	7.5%
	Supplier A	1500	H	24	24	0					
	Supplier A	1500	H	14	14	0					
	Supplier A	1500	H	6	6	0					
	Supplier A	1500	H	2	2	0					
	Supplier A	1500	H	2	2	0					
	Supplier A	1500	H	36	0	36				36	100.0%
Supplier A	1500	H	36	36	0						
Supplier A	1250	H	4	4	0						

